

ift-Richtlinie BA-01/1 2018-10

Expert Statement: 22-001954-

The results obtained can be used as evidence in accordance with the

PR02 PB-C01-03-en-01

Instruction for use

above basis.

Expert Statement

22-001954-PR03 (NW-C01-03-en-01)

Owner agtatec ag

Allmendstr. 24 8320 Fehraltorf Switzerland

Product Threshold

System designation THERMCORD3

Details Type S: System 20, 38 mm

Type S: System 20, 38 mm, telescopic

Type T: System 20, 38 mm

Type U: System 20, 38 mm, Convenience

Type U: System 20, 38 mm, Comfort

Type V: System 20, 38 mm

Special features -/-

Validity

Basis

Validity of the expert statement expires with the expiration of validity of the basis mentioned above.

This expert statement does not provide evidence of specified use as set out by the relevant national Building Supervisory Authorities.

Result

Number

Overrollability of thresholds according to ift-Richtlinie BA-01/1 2018-10



Class 5 (Type V)
Class 6 (Type S, T,U)

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim 28.02.2023

Robert Krippahl, Dipl.-Ing. (FH) Product Manager Division Testing

R. Krippahl

Thomas Krichbaumer Operating Testing Officer Building Component Testing

Thomas Wrichsaumer

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: 68C-F6A62